

# CW-SYS to LA-500 Connection

Power connection (Terminals 1 & 2) are not polarity sensitive, can be either way. Can also be powered by any other constant power source within range: 8-24 VAC or 8-28 VDC.

